

AMENDMENT OF SOLICITATION

Page of Pages

1 / 1

1. AMENDMENT/MODIFICATION NO. 0005	2. EFFECTIVE DATE APR 22, 2004
3. ISSUED BY DEPARTMENT OF THE ARMY, BALTIMORE DISTRICT CORPS OF ENGINEERS P.O. BOX 1715 BALTIMORE, MARYLAND 21203-1715 CODE: _____	
4. NAME AND ADDRESS OF CONTRACTOR (Name, street, county, State and ZIP Code)	4A. AMENDMENT OF SOLICITATION NO. W912DR-04-B-0009 4B. DATED (SEE ITEM 5) MAR 15, 2004
5. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers X is extended, ____ is not extended. BID OPENING DATE : SEE BELOW Others must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 4 and 8, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of the amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.	
6. ACCOUNTING AND APPROPRIATION DATA (If required) LITTLE FALLS PUMPING STATION ELECTRICAL IMPROVEMENTS, WASHINGTON AQUEDUCT, WASHINGTON, D.C.	
7. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) (1) THE TIME AND DATE FOR RECEIVING BIDS FOR THIS PROJECT IS EXTENDED TO 2:00 PM, LOCAL TIME APR 28, 2004. REVISE STANDARD FORM SF1442, BLOCK 13A OF THE SOLICITATION TO REFLECT THIS CHANGE. <u>SOLICITATION:</u> (2) <u>Section 00700, Page 28 of 42:</u> At the end of the list of clauses incorporated by reference add the following reference clause: "FAR 52.219-4, Notice of Price Evaluation Preference for HubZone Small Business Concerns." <u>SPECIFICATIONS:</u> (3) <u>Section 16319, Paragraph 2.4.2 Construction, first paragraph:</u> After the words "2500 MVA vacuum" inset the words: "or SF6". (4) <u>Section 16319, Paragraph 2.4.2 Construction:</u> Immediately after the first paragraph insert the following: "The Contractor may provide either new 34.5 kV, 2500 MVA vacuum circuit breakers or new 34.5 kV, 2500 MVA SF6 circuit breakers." Except as provided herein, all terms and conditions of the document referenced in Item 4A, as heretofore changed, remains unchanged and in full force.	
8. NAME AND TITLE OF SIGNER (Type or print)	9. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)
	10. DATE SIGNED